



Speaker Spotlight



David Ahles, P.E.

Principal Civil Engineer

Eastern Municipal Water District



Christian Sanders, P.E.

Environmental Engineer

CDM Smith



EMWD Brine Minimization Pilot Study

USING CCRO TO INCREASE OVERALL WATER RECOVERY IN A WATER REUSE APPLICATION

Dave Ahles
Christian Sanders

December 7, 2021



**CDM
Smith.**

The logo for the Metropolitan Water District of Southern California (EMWD), featuring a stylized wave graphic above the lowercase text "emwd".

emwd



About EMWD

- Sixth largest public water utility in California
- One of 26 member agencies of The Metropolitan Water District of Southern California (MWD)





EMWD "By the Numbers"

ESTABLISHED IN

1950



SERVES:



WATER / WASTEWATER / RECYCLED



WHOLESALE



RETAIL



POPULATION:

839,000+



555

SQUARE MILE
SERVICE AREA

ALMOST

38%

CURRENTLY
BUILT OUT






Water Supply Portfolio – 1990 and 2010


1990

Population served: 358,000



2020*

Population served: 850,000



*Total Water Supply: 135,008 AF per EMWD Comprehensive Annual Financial Report, FYE 2020




Groundwater Reliability Plus Program





Proposed Purified Water Replenishment






Pilot Plant Site





Pilot Plant Site





CCRO Schematic




Figure 1A - CC operation cycle




Figure 2B - PF operation cycle



MF: Key Design Parameters

Parameter	Units	Value
No. Trains		2
Membrane Make/Model		Toray HFU-2020AN
Membrane Material		PVDF
Manufacturing Process		Thermally Induced Phase Separation (TIPS)
Membrane Pore Size	μm	0.01
Max Instantaneous Flux	gfd	26
Minimum Design Recovery	%	90
Backwash Interval	min	45
Minimum CEB Interval	hr	24
Autostrainer Rating	micron	200
Feed Water Chemicals		Sodium Hypochlorite Liquid Ammonium Sulfate Sodium Bisulfite



MF Pilot Container






MF: Key Operating Details

Parameter	Units	Value
Operating Philosophy		Tank Level Control, Variable Flux
Operating Flux	gfd	9 to 26
Flow Rate per Train	gpm	20 to 57 gpm
Backwash Interval	min	45
Average System Recovery	%	~98
Typical CEB Interval	days	14






MF Long-Term Performance Data (Train 1)






MF Long-Term Performance Data (Train 2)





Example 24-hr MF Performance Data (Train 2)





CCRO: KEY DESIGN PARAMETERS

Parameter	Units	Value
No. Trains		1
Membrane Make/Model		FilmTec Fortilife CR100
Element Diameter	in	8
Membrane Material		Polyamide Thin-Film Composite
Minimum Salt Rejection	%	99.4
Average Flux	gfd	10
Permeate Flow Rate	gpm	70
Recovery	%	Variable
No. Stages		1
Cartridge Filter Rating	micron	1
Feed Water Chemicals		Antiscalant Sulfuric Acid



CCRO Influent WQ (10/28/20 to 03/3/21)

Parameter	Units	Avg	Max	No. Samples
Temperature	°C	20.1	23.4	8
Nitrate	mg/L as N	10.8	15.0	8
Phosphorus	mg/L as PO ₄	7.5	15.0	8
Sulfate	mg/L	171	210	8
Silica	mg/L	21	23	8
Calcium	mg/L	53.5	58.2	8
Alkalinity	mg/L as CaCO ₃	41.5	77.0	8
TDS	mg/L	611	660	8
Total Chlorine	mg/L	1.4	2.4	8

**PHOSPHATE LEVELS CONTROLLED ANTISCALANT
SELECTION AND TARGET FEED WATER pH**



Feed Water Chemical Conditioning

AWC's PROTON[®] SCALE INDEX DASHBOARD

Summary Carbonate Phosphate Sulfate Fluoride Metal Hydroxide And Oxide Sulfide Silicate **Critical Indices**


Selected Antiscalant: AWC-A-112 0.754 mg/L + 11,256 = 12,000 mg/L
Selected High pH Cleaner: AWC-C-221 2%
Selected Low pH Cleaner: AWC-C-236 2%

Adjusted Feed
pH = 5.0






CCRO – Normalized Permeate Flow vs ΔP






CCRO – Normalized Permeate Flow vs ΔP





CCRO – Normalized Salt Passage





Membrane Autopsy Findings

Tail element pulled at completion of 1st extended run @ 94%

- Membrane was in very good visual condition upon arrival. A very light foulant deposition was observed on the membrane leaves.
- Initial wet testing found that the membrane flux to be ~2.68% below manufacturer's nominal specification
- Flat sheet testing with coupons:
 - After overnight soak in D.I. water, permeability increased by ~20% over the manufacturer's nominal specification. Salt rejection was within spec.
 - After high pH (~11.9) chemical clean, permeability increased significantly
 - After low pH (~1.7) chemical clean, permeability decreased slightly
 - Overall, membrane permeability increased by approximately 45% over the nominal specification. The salt rejection, when normalized for flux, was within specification.

Membrane Autopsy Findings



FEED END



CONCENTRATE END

FEED SPACER CLEAN AND INTACT



LIGHT
FOULANT
COLLECTED
AFTER
ADDITION OF
WATER



Membrane Autopsy Conditions

- Test results suggest foulant was organic. SEM/EDS/SEI/PED analysis found no inorganic deposits on the membrane surface.
- Large increase in permeability not associated with oxidant damage:
 - Fujiwara test negative
 - Salt rejection within specification
- Membrane substantially more permeable than membrane specification.



Cost Analysis – Basis of Comparison

- Full-Scale Treatment Capacity = 2.0 mgd (2,000 AFY, 90% availability)
- Preliminary design (2018):
 - Conventional 3-stage RO to achieve 92.8% recovery
 - Average Flux = 12 gfd
 - Brine flow = 108 gpm
- Alternative: Full-Scale CCRO
 - Recovery = 94%
 - Average Flux = 10 gfd
 - Brine Flow = 89 gpm (~20% reduction vs conventional 3-stage design)



Cost Analysis – Key Assumptions

- Cost estimate compares CCRO vs 3-Stage RO equipment, feed water chemical conditioning, and brine ponds.
- All other project components (buildings, ancillary systems, pretreatment, etc.) are assumed to be identical.
- Labor costs assumed to be equal
- Operating costs include:
 - Power
 - Chemicals (sulfuric acid + antiscalant)
 - Replacement (5-yr membrane age assumed)
 - Maintenance (assume 2% of equipment cost)



Cost Analysis – CAPEX Estimate

■ 3-Stage RO

- Assume 2 x 2.0 mgd trains
- \$2,400,000 (\$1,200,000 per train)

■ CCRO

- Assume 3 x 1.0 mgd trains
- \$2,700,000 (\$900,000 per train)

Brine Ponds

- 2018 Preliminary Design Estimate = **\$9,200,000**
- 2021 Cost = \$10,580,000 (assuming 5% escalation)

AVG FLOW
108 GPM





Cost Analysis – NPV Estimate

Treatment Option	Category	Value
Conventional 3-Stage RO	Annual O&M Costs	\$369,600
	Capital Costs – 3-Stage RO	\$2,400,000
	Capital Costs – Evaporation Ponds	\$10,580,000
	30-yr NPV	\$26,508,000
	Total Yield (30 years)	60,000 AF
	NPV	\$442/AF
CCRO	Annual O&M Costs	\$449,900
	Capital Costs – 3-Stage RO	\$2,700,000
	Capital Costs – Evaporation Ponds	\$8,718,700
	30-yr NPV	\$28,033,000
	Total Yield (30 years)	60,000 AF
	NPV	\$467/AF

89/108 * \$10,580,000 ~18% Reduction



CCRO - Potential Enhancement Opportunities

- During the pilot, chemical feed conditioning based on worst-case phosphate levels (15 mg/L)
 - pH = 5.0
 - Antiscalant = 12 mg/L
- By monitoring phosphate levels in the tertiary effluent, pH and antiscalant dose could be optimized
- CCRO technology opens up the possibility for varying the feed water pH in line with recovery (i.e. reduce pH as recovery increases)



Observations and Conclusions

- Conservative MF operating parameters resulted in very reliable performance
- Stability of CCRO process similar to conventional RO treating this quality of feedwater and operating at 92-93% recovery
- CCRO capable of achieving ~30 days continuous operation between CIPs for recoveries up to 94%
- CIPs initiated based on ~15% loss in normalized permeate flow. Some reuse applications allow losses up to 20-25% prior to initiating CIPs



Observations and Conclusions

- Reliable pH monitoring/control critical to CCRO operation when phosphate is present. Advance warning systems and redundant instrumentation recommended.
- Membrane autopsy found evidence of organic fouling, but no significant mineral scaling
- 30-yr NPV for conventional 3-stage RO < 30-yr NPV for CCRO even when considering smaller ponds



CONTACT US

Dave Ahles, P.E.
Eastern MWD
Principal Civil Engineer
P: (951) 928-3777 ext. 4458
E: ahlesd@emwd.org

Christian Sanders, P.E.
CDM Smith
Environmental Engineer
P: (760) 710-4665
E: sanderscj@cdmsmith.com

Questions & Discussion

